



A G WATER TECHNOLOGIES

TECHNOLOGY

The Principal

Vinay Njn Bangali Sr. Sec School
Sangni Nagar, N. Delhi

Date
28-08-2021

Subj:- out put TDS of R.O. system

Dear Madam

As per last visit & service of your R.O. system
the out put water TDS was low water TDS:- 1050
After R.O. system (pre-water) maintain TDS:- 110

Regards

A.G. Water Technologies

Ant. Singh 9212433524

TECHNOLOGY

Deals in : All types of Water Purification, RO System, Commercial & Industrial RO Plants

Head. Off.: Main Jhajjar Chowk, Metro Pillar No. 850, Bahadurgarh-124507 (HR)
Ph.: 92124 33524 | 92124 33529 | Email-agwatertech@gmail.com